



THICKNESS VARIES SEE PLANS
 (6" MIN. OR FULL STREET SECTION UNDER CURB, WHICHEVER IS GREATER)

NOTES:

1. TREE PLANTING IN PLANTER STRIP SUBJECT TO APPROVAL OF CITY ENGINEER. CONSTRUCTION IN PLANTER STRIP SUBJECT TO ENCROACHMENT PERMIT FROM THE ENGINEERING DIVISION.
2. IN COMMERCIAL ZONES PLANTER POCKETS MAY BE REQUIRED IN LIEU OF CONTINUOUS PLANTING STRIP AS DETERMINED BY THE CITY ENGINEER.
3. SURFACE OF WALKS, CURBS, CURB FACES, AND GUTTERS SHALL BE TRUE AND STRAIGHT, OF UNIFORM WIDTH, AND FREE OF IRREGULARITIES. THE SURFACES SHALL NOT VARY MORE THAN 0.01 FOOT FROM THE EDGE OF A 10-FOOT LONG STRAIGHTEDGE.
4. IF THE FACE OF CURB TO PROPERTY LINE IS 10', SIDEWALK SHALL BE 4'-6" AND PLANTER STRIP 5'-0". FOR SIDEWALKS LESS THAN 5 FEET WIDTH, LANDINGS (5 FEET X 5 FEET) SHALL BE PROVIDED AT 200-FOOT INTERVALS. LOCATIONS SHALL BE SHOWN ON THE PLANS.
5. COMPACT AGGREGATE SUBBASE AND AGGREGATE BASE IN THE STREET AND UNDER THE CURB TO 95% RELATIVE COMPACTION (MIN). COMPACT AGGREGATE SUBBASE AND/OR AGGREGATE BASE UNDER THE SIDEWALK TO 90% RELATIVE COMPACTION (MIN). COMPACT ALL SUBGRADE TO 90% RELATIVE COMPACTION (MIN).
6. CONCRETE SHALL BE 6 SACK.

<h2 style="margin: 0;">CITY OF FREMONT</h2> <h3 style="margin: 0;">STANDARD DETAILS</h3> <h3 style="margin: 0;">TYPE "A" CURB, GUTTER AND SIDEWALK</h3>				DATE APPROVED BY CITY COUNCIL 04/11/06							
				RESOLUTION NO. 2006-31							
				CITY ENGINEER							
FILE NO. SD-03-06.DWG	SCALE 1 1/2" = 1'-0"	DRAWN DC	CHECKED KC	DATE 03/14/06	DWG NO. SD-3						
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">NO.</th> <th style="width: 40%;">REVISED</th> <th style="width: 50%;">DATE</th> </tr> </thead> <tbody> <tr> <td colspan="3" style="text-align: center;">REVISIONS</td> </tr> </tbody> </table>				NO.	REVISED	DATE	REVISIONS			1 of 1	
NO.	REVISED	DATE									
REVISIONS											