



NOTES:

1. SURFACE OF WALKS, CURBS, CURB FACES, AND GUTTERS SHALL BE TRUE AND STRAIGHT, OF UNIFORM WIDTH, AND FREE OF IRREGULARITIES. THE SURFACES SHALL NOT VARY MORE THAN 0.01 FOOT FROM THE EDGE OF A 10-FOOT LONG STRAIGHTEDGE.
2. FOR CERTAIN CIRCUMSTANCES WHEN SIDEWALK IS LESS THAN 5 FEET WIDE, LANDINGS (5 FEET X 5 FEET) SHALL BE PROVIDED AT 200-FOOT INTERVALS. LOCATIONS SHALL BE SHOWN ON THE PLANS.
3. COMPACT AGGREGATE SUBBASE AND AGGREGATE BASE IN THE STREET AND UNDER THE CURB TO 95% RELATIVE COMPACTION (MIN). COMPACT AGGREGATE SUBBASE AND/OR AGGREGATE BASE UNDER THE SIDEWALK TO 90% RELATIVE COMPACTION (MIN). COMPACT ALL SUBGRADE TO 90% RELATIVE COMPACTION (MIN).
4. CONCRETE SHALL BE 6 SACK.

CITY OF FREMONT
STANDARD DETAILS
TYPE "C" MONOLITHIC CURB,
GUTTER, AND SIDEWALK

DATE APPROVED BY CITY COUNCIL
 04/11/06

RESOLUTION NO. 2006-31

Ham Hughes

CITY ENGINEER

NO.	REVISED	DATE
REVISIONS		

FILE NO.
 SD-05-06.DWG

SCALE
 1 1/2" = 1'-0"

DRAWN
 DC

CHECKED
 KC

DATE
 03/14/06

DWG NO.
 SD-5

1 of 1