



Size	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"
A	2 3/4"	3"	3 3/4"	4 7/16"	4 15/16"	6 7/8"
B	2 1/4"	2 9/16"	2 3/4"	3 5/8"	3 7/8"	5 1/8"
C	1/4"	3/8"	3/8"	3/4"	3/4"	1"
Wt	.75	1.38	2.13	3.13	4.5	7

NOTES:

1. BODY AND CAP SHALL BE BRONZE ASTM B62; SCREEN SHALL BE 20 MESH STAINLESS STEEL; GASKET SHALL BE NON-ASBESTOS; ENDS SHALL BE THREADED ANSI/ASME B1.20.1
2. WORKING PRESSURE SHALL BE NON-SHOCK, 200 PSI @ 150 DEGREES
3. REFER TO CITY STANDARD DETAIL LSD-14 FOR ALL MATERIALS

<h2 style="margin: 0;">CITY OF FREMONT</h2> <h3 style="margin: 0;">STANDARD DETAILS</h3> <h3 style="margin: 0;">CITY STANDARD</h3> <h3 style="margin: 0;">IRRIGATION WYE STRAINER</h3>			DATE APPROVED BY CITY COUNCIL 12/13/11														
			RESOLUTION NO. 2006-31														
			CITY ENGINEER														
APPR	REVISED	DATE	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 20%;">FILE NO.</td> <td style="width: 20%;">SCALE</td> <td style="width: 20%;">DRAWN</td> <td style="width: 20%;">CHECKED</td> <td style="width: 20%;">DATE</td> <td style="width: 20%;">DWG NO.</td> </tr> <tr> <td style="text-align: center;">LSD-26.DWG</td> <td style="text-align: center;">1" = 1'-0"</td> <td style="text-align: center;">AK/MM/PM</td> <td style="text-align: center;">RER</td> <td style="text-align: center;">NOV. 2005</td> <td style="text-align: center;">LSD-26</td> </tr> </table>			FILE NO.	SCALE	DRAWN	CHECKED	DATE	DWG NO.	LSD-26.DWG	1" = 1'-0"	AK/MM/PM	RER	NOV. 2005	LSD-26
FILE NO.	SCALE	DRAWN				CHECKED	DATE	DWG NO.									
LSD-26.DWG	1" = 1'-0"	AK/MM/PM	RER	NOV. 2005	LSD-26												
REVISIONS			1 of 1														