



NOTES:

1. HYDRANTS SHALL BE THE EAST BAY CALIFORNIA FIRE HYDRANT MANUFACTURED UNDER LICENSE WITH THE EAST BAY MUNICIPAL UTILITY DISTRICT AS MANUFACTURED BY CLOW OR APPROVED EQUAL.
2. HYDRANT SHALL BE INSTALLED IN ACCORDANCE WITH CURRENT ACWD SPECIFICATIONS AND STANDARD DRAWINGS.
3. HYDRANTS SHALL BE PAINTED:
 - a. KELLY MOORE CURB MARKING #1473-131 SAFETY YELLOW OR EQUAL.
 - b. SHERWIN WILLIAMS METALATEX "SAFETY YELLOW" NO. 342Y37 OR EQUAL.
4. BLUE RAISED REFLECTIVE PAVEMENT MARKERS SHALL BE INSTALLED INLINE WITH THE HYDRANT IN THE PAVEMENT ACCORDING TO LATEST MUTCD.

APPR	REVISION	DATE	CITY OF FREMONT STANDARD DETAILS FIRE HYDRANT			DATE APPROVED BY CITY COUNCIL		
<i>LB</i>	GENERAL REVISION	7/22				4/11/2006		
						RESOLUTION NO.		
						2006-31		
						CITY ENGINEER		
FILE NO.			SCALE	DRAWN	CHECKED	DATE	DWG NO.	1 OF 1
SD-34-22.DWG			NOT TO SCALE	DC	AR	5/21/2007	SD-34	1 OF 1